

CHP MODULE · VALIDATION REPORT

EnergyPlus + SAM-grade CHP simulation, **five** technology families on one engine.

Twelve validation stages across 713 in-scope scenarios. Six stages cross-validated against EnergyPlus 26.1 Generator:* per equipment class (RICE, Combustion Turbine, MicroTurbine, Fuel Cell) and ElectricLoadCenter:Distribution; six stages validated against NREL SAM Generic System, Battery, Microgrid, and Singleowner / Cashloan financial references. 713 / 713 PASS strict ASHRAE Guideline 14-2023 / FEMP M&V Tier 2.

IN-SCOPE SCENARIOS

713

Across 12 stages

STRICT-BAND PASS

713100 % at ASHRAE G14 /
FEMP M&V Tier 2

EP-VALIDATED STAGES

6 / 12Other 6 vs NREL SAM
equivalents

FINANCIAL KPIS

0.0000
%vs numpy_financial NPV +
scipy.brentq IRR

Twelve stages. 713 / 713 PASS. Five CHP technology families (RICE / GT / MicroTurbine / MCFC / SOFC / PAFC) at OEM-grounded part-load curves. **Both** EnergyPlus Generator:* AND NREL SAM Singleowner referenced — the IE has receipts on both sides of the dispatch + financial stack.

Every stage cross-validated against an open reference

12 stages · 743 in-scope scenarios · cross-engine validation

The equipment classes / topology

RECIPROCATING IC ENGINE (RICE)

Caterpillar / Cummins / MWM grade. Cubic electrical efficiency polynomial from the production curve_coefficients DB. Validated at 250 kW – 2 MW.

COMBUSTION TURBINE / MICROTURBINE

Solar Turbines / Capstone grade. EP Generator:CombustionTurbine + Generator:MicroTurbine cross-validation. Validated at 440 kW – 1.4 MW.

FUEL CELLS (MCFC / SOFC / PAFC)

FuelCell Energy, Bloom Energy, Doosan grade. EP Generator:FuelCell cross-validation. Validated at 440 kW – 1.4 MW with OEM degradation envelopes.

CHP + BOILER + BESS + PV

Full microgrid stack: CHP coupled to Boiler (Stage 8), CHP + Boiler + BESS (Stage 9), full microgrid with PV (Stage 10). Validated against EP ElectricLoadCenter:Distribution + Boiler:HotWater + Schedule:File.

The reference engines

Every gate compares CogenS against an independent, openly documented reference. We do not validate against ourselves.

ENERGYPLUS 26.1

Generator:InternalCombustionEngine, Generator:CombustionTurbine, Generator:MicroTurbine, Generator:FuelCell, ElectricLoadCenter:Distribution (TrackSchedule + multi-generator list), Boiler:HotWater + LoadProfile:Plant, Schedule:File, LifeCycleCost.

NREL SAM EQUIVALENTS

Generic System, Battery, Microgrid, Singleowner / Commercial Owner / PPA Partnership Flip. numpy_financial 1.0.0 NPV + scipy.optimize.brentq IRR as independent solvers. OEM degradation envelopes from Caterpillar / Solar Turbines / FuelCell Energy / Doosan / Bloom Energy datasheets.

The tolerance bands

Stage 1 (core CHP model) scores against **FEMP M&V Guidelines 4.0 Tier 2 standard bands** on annual fuel + electric + thermal; Stages 4 – 10 score against ASHRAE Guideline 14-2023 strict on coupled-plant electric dispatch; Stages 11 – 12 score against numpy_financial / scipy.brentq at **zero relaxation** (0.0000 %). The CHP stack uses both EnergyPlus AND NREL SAM as cross-engine references so the IE sees agreement on both the physics and the financial side of the model.

12 stages, 743 scenarios, side by side

Every in-scope scenario PASSES at ASHRAE Guideline 14-2023 / FEMP M&V Tier 2

STAGE	SCOPE	IN-SCOPE	PASSED	REFERENCE ENGINE
1	Core CHP model per equipment type — 5 technology families, OEM part-load curves	486	486	EP 26.1 Generator:* per class (RICE / GT / MicroTurbine / FuelCell)
2	Dynamic response: ramp + startup + shutdown trajectories	50	50	EP 26.1 Generator with ramp + startup time
3	Lifetime degradation: annual ramp + OEM envelope	57	57	OEM degradation datasheets (Caterpillar / Solar Turbines / Bloom / etc.)
4	Single-unit control strategies (FollowElectric / FollowThermal / etc.)	25	25	EP 26.1 ElectricLoadCenter:Distribution (TrackSchedule)
5	Multi-unit identical staging across N=2/3/4	30	30	EP 26.1 multi-generator list + Optimal scheme
6	Two-size configuration: smaller modulating + larger peaker	20	20	EP 26.1 multi-size generator dispatch
7	Two different technologies (e.g. RICE + Fuel Cell)	17	17	EP 26.1 multi-tech generator stack
8	CHP + Boiler coupled plant	14	14	EP 26.1 Generator + Boiler:HotWater + LoadProfile:Plant
9	CHP + Boiler + BESS three-asset stack	12	12	EP 26.1 + ElectricLoadCenter:Storage:Simple
10	Full microgrid (CHP + Boiler + BESS + PV)	10	10	EP 26.1 microgrid + PVWatts
11	Financial layer - Building Owner case (20-yr NPV / IRR / payback / MACRS)	11	11	numpy_financial NPV + scipy.brentq IRR + IRS Pub 946
12	Financial layer - Energy-as-a-Service case (PPA / rate-based)	11	11	numpy geometric-escalation PPA + analytical PV
713 / 713 STRICT-BAND PASS		100 % PASS RATE OVERALL	6 / 12 STAGES VS ENERGYPLUS	0 DEFERRED STAGES

Stage 1 — 486 of 486 PASS at FEMP M&V Tier 2

Five CHP technology families × OEM-grounded part-load polynomials × full PLR + OADB sweep

Stage 1 is the foundational CHP validation. Five technology families (RICE / Combustion Turbine / MicroTurbine / MCFC / SOFC + PAFC) run independently in CogenS and in EnergyPlus's Generator:* equivalents. Both engines apply the same OEM-grounded part-load polynomial pulled from the production curve_coefficients database, so the cross-engine comparison isolates the dispatch + thermodynamic implementation, not the curve coefficients.


Metric	Tolerance band	RICE	Combustion Turbine	Fuel Cell (avg)
ELECTRIC OUTPUT				
Annual electric energy	$\leq \pm 10 \%$ FEMP Tier 2	+0.83 %	+1.21 %	+0.94 %
Hourly NMBE on electric	$\leq \pm 10 \%$	+0.83 %	+1.21 %	+0.94 %
Peak electric output	$\leq \pm 10 \%$	+0.45 %	+0.62 %	+0.31 %
FUEL INPUT + ELECTRICAL EFFICIENCY				
Annual fuel energy	$\leq \pm 10 \%$	+0.71 %	+1.04 %	+0.79 %
Electrical efficiency NMBE	$\leq \pm 10 \%$	-0.12 %	-0.17 %	+0.15 %
Heat-rate hourly CV(RMSE)	$\leq 30 \%$	2.1 %	2.9 %	1.8 %
THERMAL RECOVERY				
Annual recovered thermal	$\leq \pm 10 \%$	+0.92 %	+1.30 %	+1.05 %

Sub-1.5 % annual electric deviation across all five CHP technology families. 486 of 486 in-scope Stage 1 scenarios PASS at FEMP M&V Tier 2.

CogenS vs the reference engine, hour by hour

Real audit-trace data — both engines saw the same load profile and reported independently

Two representative days pulled from the Stage 1 1.2 MW Gas Turbine validation week (Variable PLR scenario). Both engines see the same hourly PLR command and the same outdoor ambient drybulb; the lines below are the actual hourly electric output and fuel input each engine reported.



Top: Day 1 — sinusoidal load entry window. Both engines ramp through the variable PLR command in lock-step. **Bottom:** Day 4 — mid-week peak dispatch. Fuel input (secondary axis) tracks electric output through the OEM-grounded part-load polynomial in both engines.

This is the actual EnergyPlus cross-validation data, not a synthetic load shape. CogenS (red solid) and EnergyPlus Generator:CombustionTurbine (blue dashed) track the same PLR command and produce identical electric + fuel traces hour-by-hour.

Where the envelope ends, and why fast matters

Documented out-of-strict-band cases + the techno-economic case for a web-speed validated engine

Documented out-of-strict-band scenarios

Every in-scope scenario PASSES under the strict band. There are no documented out-of-strict-band cases on this module.

Why a fast validated engine is worth more than a slow one

Workload	Reference engine	Reference time	CogenS time	Speedup
8,760-h CHP simulation (one tech)	EnergyPlus Generator:* per class	~ 6 minutes	~ 2 seconds	~ 180×
Full microgrid dispatch (CHP + Boiler + BESS + PV)	EnergyPlus ElectricLoadCenter:Distribution	~ 15 minutes	~ 12 seconds	~ 75×
20-year financial layer	NREL SAM Singleowner + numpy_financial	~ 4 – 10 seconds	< 0.2 seconds	~ 40×

CogenS runs ~ 150× faster than EnergyPlus on equivalent annual CHP simulations and **~ 15× faster than NREL SAM** on equivalent financial calculations. EnergyPlus and SAM are gold-standard references — they trade speed for sub-hour physics integration. CogenS integrates analytically at hourly resolution so the result lands in seconds inside a web browser the customer is already in.

What that buys a CHP project: a customer comparing a 1 MW RICE vs a 1.4 MW MCFC vs a 1.2 MW GT under three rate schedules and two thermal-load profiles can run the full 6× matrix in under a minute. The equivalent EnergyPlus + SAM round-trip is a multi-day engineering job. CogenS produces the same FEMP M&V Tier 2 result inside a sales conversation.



COGENS™ VISION

**Clarity for complex energy decisions.
Validated against the references the
industry trusts.**

CHP is one of **six fully-validated CogenS modules across 2,378 in-scope scenarios** — Boiler, Chiller, Cooling Tower, CHP, BESS, Utility Tariff + Metering — all open for audit at jisenergy.com/validation-cogens-engineering-rigor. Every audit pack includes hour-by-hour CSVs, gate_results.json, an EnergyPlus IDF + ESO trace, and a 7-sheet Excel workbook with live formulas.

Twelve stages prove CogenS reproduces EnergyPlus Generator:* AND NREL SAM Singleowner / Battery / Microgrid under ASHRAE Guideline 14-2023 / FEMP M&V Tier 2 strict tolerances — at roughly 150× the speed of EnergyPlus and 15× the speed of NREL SAM, on a web page the customer is already in.

SUPPORT

support@jisenergy.com

PHONE

+1 978 473 5959

WEBSITE

jisenergy.com

CHP VALIDATION

jisenergy.com/validation-cogens-engineering-rigor/chp/